

Slip Check to AS/NZS 4586 Appendix A - Wet Pendulum PPX 1641

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

12 June 2013

Test Report No. R5128f

Slip Resistance Classification of New Pedestrian Surface Materials


AS/NZS 4586:2004 Appendix A (Wet Pendulum Test)

The slip resistance Classification have been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface after classification. Standards Australia HB 197, *An introductory guide to the slip resistance of pedestrian surface materials*, provides guidelines for the selection of slip resistant pedestrian surfaces classified in accordance with AS/NZS 4586. It is recommended that this test report be read in conjunction with AS/NZS 4586 and HB 197.

Requested by: Pebblecrete In-situ Pty Ltd
Client Address: 238 Woodpark Road
Smithfield NSW 2164
Product Manufacturer: Supplied by Pebblecrete In-situ Pty Ltd
Product Description: PPX 1641
Test conducted according to: AS/NZS 4586:2004 Appendix A
Location: Slip Check Pty Ltd Test Facilities, Seven Hills NSW
Conducted by: Ryan Voorderhake
Date: 07 June 2013
Sample: Unfixed
Rubber slider used: Four S
Temperature: 18°C
Cleaning: None
Conditioned: Grade P 400 paper dry

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	66	69	65	67	66

Mean BPN of Sample:	67
Class:	V



Martin Daniel
Materials Scientist