

## **Slip Check to AS/NZS 4586 Appendix A - Wet Pendulum PPX 756**

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

12 June 2013

## Test Report No. R5128c

### Slip Resistance Classification of New Pedestrian Surface Materials


AS/NZS 4586:2004 Appendix A (Wet Pendulum Test)

The slip resistance Classification have been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface after classification. Standards Australia HB 197, *An introductory guide to the slip resistance of pedestrian surface materials*, provides guidelines for the selection of slip resistant pedestrian surfaces classified in accordance with AS/NZS 4586. It is recommended that this test report be read in conjunction with AS/NZS 4586 and HB 197.

Requested by: Pebblecrete In-situ Pty Ltd  
Client Address: 238 Woodpark Road  
Smithfield NSW 2164  
Product Manufacturer: Supplied by Pebblecrete In-situ Pty Ltd  
Product Description: PPX 756  
Test conducted according to: AS/NZS 4586:2004 Appendix A  
Location: Slip Check Pty Ltd Test Facilities, Seven Hills NSW  
Conducted by: Ryan Voorderhake  
Date: 07 June 2013  
Sample: Unfixed  
Rubber slider used: Four S  
Temperature: 19°C  
Cleaning: None  
Conditioned: Grade P 400 paper dry

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	65	66	65	65	65

<b>Mean BPN of Sample:</b>	<b>65</b>
<b>Class:</b>	<b>V</b>



Martin Daniel  
Materials Scientist